

TAYLORS FIRE & SEWER DISTRICT

STANDARD SANITARY SEWER CONSTRUCTION NOTES

1. UNLESS OTHERWISE NOTED, SEWER INSTALLATION SHALL COMPLY WITH THE *SEWER CONNECTION STANDARDS*, *SANITARY SEWER CONNECTION SPECIFICATIONS*, AND *MINIMUM CONSTRUCTION STANDARDS* SECTIONS OF THE *TAYLORS FIRE & SEWER DISTRICT (TFSD) STANDARDS FOR SEWER CONSTRUCTION & FEE POLICY* (E.G. TFSD STANDARDS), CURRENT CONDITIONS, FOUND AT WWW.TAYLORSDISTRICT.ORG/WP/NEW-CONSTRUCTION-STANDARDS/.
2. SEWER INSPECTION, TESTING, AND FINAL ACCEPTANCE SHALL COMPLY WITH THE *INSPECTION AND TESTING* AND *FINAL ACCEPTANCE* SECTIONS OF THE TFSD STANDARDS REFERENCED ABOVE, UNLESS NOTED OTHERWISE.
3. TFSD WILL CAMERA THE LINES PRIOR TO APPROVING FOR SERVICE. DEVELOPER/CONTRACTOR SHALL BE RESPONSIBLE FOR CORRECTING ANY DEFICIENCIES NOTED. TFSD WILL CAMERA THE LINES AT THE END OF THE ONE-YEAR WARRANTY PERIOD. DEVELOPER/CONTRACTOR SHALL BE RESPONSIBLE FOR CORRECTING ANY DEFICIENCIES NOTED.
4. SDR-26 PIPE IS REQUIRED FOR ALL PIPE TO BE DEDICATED TO TFSD, UNLESS NOTED OTHERWISE.
5. "DOGHOUSE" MANHOLES MAY NOT BE USED.
6. CONNECTION OF SERVICE LINES DIRECTLY TO MANHOLES IS NOT ALLOWED, UNLESS NOTED OTHERWISE.
7. MANHOLES SHALL HAVE "GATOR WRAP" AT ALL JOINTS. MANHOLE COVERS SHALL HAVE THE TFSD LOGO DESIGN TO PREVENT THEFT.
8. TFSD REQUIRES THAT THE SERVICE CONNECTION (6" SDR 26") TO THE MAIN LINE BE AT 60° (@ 11 O'CLOCK) AND ALL NEWLY CONSTRUCTED, REPLACED, OR REHABILITATED LINES SHALL BE CONSTRUCTED TO INCLUDE A FOUR (4") INCH CLEAN-OUT PLACED AT A GRADE, AS CLOSE TO THE PROPERTY/PUBLIC RIGHT-OF-WAYS BOUNDARY LINE AS

PRACTICAL. THE CLEAN-OUT SHALL BE CONSTRUCTED WITH A PVC SCREW CAP AND WATER VALVE BOX LABELED 'SEWER.'

9. ANY SEWER LINE RUNNING UNDER STORM DRAIN LINE SHALL BE DUCTILE IRON PIPE (MINIMUM 7' ON EITHER SIDE OF THE LINE). THE CONNECTION BETWEEN DIP AND PVC SHALL BE VIA A FERNCO SERIES 5000 STAINLESS STEEL STRONGBACK NON-SHEAR TYPE COUPLING, WITH EXACT MODEL NO. SHOWN ON THE PROFILE.
10. IN ACCORDANCE WITH 811 REQUIREMENTS, A MAGNETIC DETECTION TAPE OR TRACER WIRE SHALL BE INSTALLED DIRECTLY OVER EACH SANITARY SEWER LINE AT A DEPTH OF 3'-0" TO 3'-6". A SAMPLE OF THE PRODUCT SHALL BE PROVIDED TO TFSD FOR APPROVAL AT LEAST TEN (10) DAYS PRIOR TO INSTALLATION.
11. CONTRACTOR SHALL CONTACT TFSD A MINIMUM OF 72-HOURS PRIOR TO ANY SEWER CONSTRUCTION & SCHEDULE A PRE-CONSTRUCTION CONFERENCE ON SITE TO REVIEW THE DESIGN & COORDINATE FIELD INSPECTIONS BEFORE, DURING, AND AFTER CONSTRUCTION.
12. IN THE CASE OF EITHER UNCERTAINTY OR DISCREPANCY BETWEEN THE TFSD STANDARDS AND APPROVED CONSTRUCTION DRAWINGS DURING CONSTRUCTION CONTRACTOR SHALL CONTACT TFSD IMMEDIATELY FOR RESOLUTION.